

City of Isle of Palms, SC  
Requests for Bids (RFB 2048-06)  
Repair and Resurface two (2) Tennis Courts

Addendum #1 – Answer to Question

1. Since there was not a mandatory site visit , most bids or this kind will let the bidders know how many feet of crack repair is needed.in order to do a bid I need to know how many feet of acrylic crack repair I need to do. The resurfacing, lines, post and nets are clear.

**Answer:** To repair all the cracks on the double courts it will take at least and not less than 1480' of Riteway.